



CONCRETE SEALANTS INC.

P.O. Box 176 • New Carlisle, Ohio 45344

Telephone (937) 845-8776 • 1-800-332-SEAL (7325) • Fax (937) 845-3587

Web Site: <http://www.conseal.com>

E-mail: hello@conseal.com

Certificate of Conformance

This is to certify that the material listed below conforms to the following specifications. The material meets or exceeds the listed performance requirements.

Product: ConSeal CS-102B Bitumen/Butyl Sealant

Performance: Testing of this product meets the requirements set forth in ASTM C-990 section 10.1.

Specifications: This product meets or exceeds the requirements of Federal Specification SS-S-210 (210A), AASHTO M198B, and ASTM C-990-91.

Chemical Composition and Properties:

Hydrocarbon blends % by weight (ASTM D4):	50% min.
Inert mineral filler % by weight (SS-S-210A):	30% - 50%
Volatile matter % by weight (ASTM D6):	0% - 3%
Specific Gravity (ASTM D71)	1.15 – 1.40
Ductility (ASTM D113)	5.0 min.
Softening point (ASTM D36)	320° min.
Penetration @ 77° (ASTM D217)	50 – 120 dmm

Pursuant to the buy American provisions of the American Recovery and Reinvestment Act (ARRA) Section 1605 of 2009, all preformed sealant tapes and concrete coatings sold by Concrete Sealants, Inc. qualify as goods produced in the United States. All components of these products are manufactured in Tipp City, Ohio using various raw materials, also purchased in the United States.

Sincerely,

Tim Frazier

Tim Frazier
Technical Director