

January 3, 2023

Certificate of Conformance

This is to certify that the material listed below conforms to the following specifications. The material meets or exceeds the listed performance requirements.

Product: ConSeal CS-213 Geotextile Barrier

Performance: Testing of the butyl rubber content meets the requirements set forth in ASTM C-990.

Chemical Composition and Properties:

Hydrocarbon blends % by weight (ASTM D4)	50% min.
Inert mineral filler % by weight (AASHTO T111)	30% min.
Volatile matter % by weight (ASTM D6):	3% max.
Specific Gravity (ASTM D71)	1.20 – 1.30
Ductility (ASTM D113)	5.0 min.
Flash Point (ASTM D92)	320° min.
Penetration @ 77° (ASTM D217)	50 – 120 dmm

Pursuant to the provisions of the Buy American Act (BAA) under Section 1605 of the American Recovery and Reinvestment Act (ARRA), all preformed sealant tapes, concrete admixtures and concrete coatings sold by Concrete Sealants, Inc. qualify as goods produced in the United States. All components of these products are manufactured in Tipp City, Ohio using various raw materials, also purchased in the United States.

Sincerely,



Van R. Foster
Research and Development Director,
Concrete Sealants, Inc.